



CLIENT: Client 1

PROJECT: Geotechnical Investigations

LOCATION: 33 Hedgehog Road, New Brighton

Scala Penetrometer Testing

Date Tested:
20/05/2019

Tested By:
EW

Test ID	HA-1	HA-2	HA-3							
Test from (m)	0.0m	0.0m	0.0m							
Depth (m)	Blows/100mm penetration									
0.1	2	3	2							
0.2	3	4	4							
0.3	4	5	5							
0.4	3	2	3							
0.5	2	4	2							
0.6	1	6	3							
0.7	3	8	4							
0.8	7	7	5							
0.9	3	5	3							
1.0	5	5	3							
1.1	4	7	2							
1.2	3	11	5							
1.3	2	12	6							
1.4	2	10	4							
1.5	2	7	4							
1.6	3	5	4							
1.7	9	6	4							
1.8	20+	7								
1.9	12	8								
2.0	7	8								
2.1	6	7								
2.2	5	6								
2.3	5	5								
2.4	5									
2.5	3									
2.6	2									
2.7	5									
2.8	9									
2.9	11									
3.0										

In-situ field testing in accordance with Scala Penetrometer Testing: NZS 4402:1988, Test 6.5.2, Dynamic Cone Penetrometer